

Inductive proximity switches



(€ 0102

General specifications	
Switching element function	DC Dual Break function
Rated operating distance s _n	3 mm
Installation	embeddable
Assured operating distance s _a	0 2.3 mm
Reduction factor r _{Al}	0.46
Reduction factor r _{Cu}	0.45
Reduction factor r _{V2A}	1.25
Reduction factor r _{Ms}	0.63
Nominal ratings	
Switching frequency f	0 100 Hz
Hysteresis H	typ. 5 %
Reverse polarity protection	Protected against reverse polarity
Short-circuit protection	pulsing
Design data	
Indication of the switching state	LED, yellow
Standard conformity	
Standards	DIN EN 60947-5-6 (NAMUR)
Ambient conditions	
Ambient temperature	-25 100 °C (248 373 K)
Storage temperature	-40 100 °C (233 373 K)
Mechanical specifications	
Connection type	120 mm PVC
Core cross-section	4 x 0.14
Housing material	PBT/PPS
Protection degree	IP67
General information	
Use in the hazardous area	see instruction manuals
Category	2G

Connection type:



Inductive proximity switches

ATEX 2G

Instruction

Device category 2G

Directive conformity Standard conformity

CE symbol

Ex-identification

EC-Type Examination Certificate

Appropriate type

Effective internal capacitance Ci

Effective internal inductance Li

General

Highest permissible ambient temperature

Installation, Comissioning

Maintenance

[Fett]Special conditions

Protection from mechanical danger

Manual electrical apparatus for hazardous areas

for use in hazardous areas with gas, vapour and mist

94/9/EC

EN 50014:1997, EN 50020:1994 Ignition protection "Intrinsic safety"

Use is restricted to the following stated conditions

€0102

⟨Ex⟩ II 2G EEx ia IIC T6

TÜV 99 ATEX 1479 X

NCN3-F25.-N4..

 \leq 100 nF ; a cable length of 10 m is considered. The value is applicable for the sensor circuit

 \leq 100 μH ; a cable length of 10 m is considered. The value is applicable for the sensor circuit

The apparatus has to be operated according to the appropriate data in the data sheet and in this instruction manual. The EU prototype test certificate must be observed. The special conditions must be adhered to!

The temperature ranges, according to temperature class, are given in the EU prototype test certificate.

Laws and/or regulations and standards governing the use or intended usage goal must be observed. The intrinsic safety is only assured in connection with an appropriate related apparatus and according to the proof of intrinsic safety.

No changes can be made to apparatus, which are operated in hazardous areas. Repairs to these apparatus are not possible.

When used in the temperature range below -20°C the sensor should be protected from knocks by the provision of an additional housing.