	Dimensions		
	Dimensions		
		M20 :	
CC 0102 CC S COUS APPROVED			
Model Number	¢	1(-	
NCN50-FP-N0-P1			
Features		└-{©	
• 50 mm non-flush			65
	Technical Data		
Connection	General specifications		
	Switching element function Rated operating distance	s _n	NAMUR, NC 50 mm
	Installation	Sn	NAMUR
	Output polarity Assured operating distance	sa	0 40.5 mm
	Reduction factor r _{Al} Reduction factor r _{Cu}		0.4 0.35
	Reduction factor r ₃₀₄ Nominal ratings		0.8
	Installation conditions		
	A B		40 mm 150 mm
	F		240 mm
	Nominal voltage Switching frequency	U _o f	8.2 V (R _i approx. 1 kΩ) 0 80 Hz
	Hysteresis Reverse polarity protection	Н	05 typ.3 % reverse polarity protected
	Short-circuit protection		yes
	Current consumption Measuring plate not detected		≥ 3 mA
	Measuring plate detected Time delay before availability	t _v	≤ 1 mA ≤ 20 ms
	Switching state indication	v	LED, yellow
	Ambient conditions Ambient temperature		-25 100 °C (-13 212 °F)
	Storage temperature Mechanical specifications		-40 100 °C (-40 212 °F)
	Connection type		screw terminals
	Core cross-section Housing material		up to 2.5 mm ² PBT
	Sensing face Protection degree		PBT IP67
	General information		
	Use in the hazardous area Category		see instruction manuals 1G; 2G; 1D
	Compliance with standards and d	irective	s
	Standard conformity NAMUR		EN 60947-5-6:2000 IEC 60947-5-6:1999
	Electromagnetic compatibility		NE 21:2007
	Standards		EN 60947-5-2:2007 IEC 60947-5-2:2007
	Approvals and certificates		
	FM approval Control drawing		116-0165F
	UL approval		cULus Listed, General Purpose
	CSA approval CCC approval		cCSAus Listed, General Purpose Products with a maximum operating voltage of ≤36 V do not bear a
	ουο αρμιοναι		CCC marking because they do not require approval.
	1		

Release date: 2013-02-10 21:44 Date of issue: 2013-02-11 106325_eng.xml

 Subject to modifications without notice

 Pepperl+Fuchs Group
 US

 www.pepperl-fuchs.com
 fa-info

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776-4411 fa-info@pepperl-fuchs.com

Copyright Pepperl+Fuchs Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



ATEX 1G	
Instruction	Manual electrical apparatus for hazardous areas
Device category 1G Directive conformity Standard conformity	for use in hazardous areas with gas, vapour and mist 94/9/EG EN 60079-0:2009, EN 60079-11:2007, EN 60079-26:2007 Ignition protection "Intrinsic safety" Use is restricted to the following stated conditions
CE marking	€€0102
Ex-identification	🕼 II 1G Ex ia IIC T6 Ga
EC-Type Examination Certificate Appropriate type	PTB 00 ATEX 2032 X NCN50-FP-N0
Effective internal capacitance Ci	\leq 220 nF ; a cable length of 10 m is considered.
Effective internal inductance L _i	\leq 360 μH ; a cable length of 10 m is considered. The sum takes have to be set the state of
General	The apparatus has to be operated according to the appropriate data in the data sheet and in this instruction manual. The EC-Type Examination Certificate has to be observed. The special conditions must be adhered to!
Highest permissible ambient temperature	The temperature ranges, according to temperature class, are given in the EC-Type Examination Certificate. Note: Use the temperature table for category 1 !!! The 20 % reduction in accordance with EN 1127-1:2007 has already been accounted for in the temperature table for category 1.
Installation, Comissioning	Laws and/or regulations and standards governing the use or intended usage goal must be observed. The intrinsic safety is only assured in connection with an appropriate related apparatus and according to the proof of intrinsic safety. The associated apparatus must satisfy the requirements of category ia. Due to the possible danger of ignition, which can arise due to faults and/or transient currents in the equipotential bonding system, galvanic isolation of the power supply and signal circuit is preferable. Associated apparatus without electrical isolation must only be used if the appropriate requirements of IEC 60079-14 are met.
Maintenance	No changes can be made to apparatus, which are operated in hazardous areas. Repairs to these apparatus are not possible.
Specific conditions	
Protection from mechanical danger	When used in the temperature range below -20 $^{\circ}\mathrm{C}$ the sensor should be protected from knocks by the provision of an additional housing.
Electrostatic charging	Non-permissible electrostatic charges should be avoided on the plastic housing parts.

621 776-4411 Singa erl-fuchs.com fa-info@



ATEX 2G

Instruction

Device category 2G Directive conformity Standard conformity

CE marking

Ex-identification EC-Type Examination Certificate Appropriate type Effective internal capacitance C_i Effective internal inductance L_i General

Highest permissible ambient temperature

Installation, Comissioning

Maintenance

Specific conditions

Protection from mechanical danger

Electrostatic charging

Manual electrical apparatus for hazardous areas

for use in hazardous areas with gas, vapour and mist 94/9/EG EN 60079-0:2009, EN 60079-11:2007 Ignition protection "Intrinsic safety" Use is restricted to the following stated conditions $C \in 0102$

⟨E⟩ II 1G Ex ia IIC T6 GaPTB 00 ATEX 2032 XNCN50-FP-N0..

 \leq 220 nF ; a cable length of 10 m is considered.

 $\leq 360~\mu H$; a cable length of 10 m is considered. The apparatus has to be operated according to the appropriate data in the data sheet and in this instruction manual. The EC-Type Examination Certificate has to be observed. The special conditions must be adhered to!

The temperature ranges, according to temperature class, are given in the EC-Type Examination Certificate.

Laws and/or regulations and standards governing the use or intended usage goal must be observed. The intrinsic safety is only assured in connection with an appropriate related apparatus and according to the proof of intrinsic safety.

No changes can be made to apparatus, which are operated in hazardous areas. Repairs to these apparatus are not possible.

When used in the temperature range below -20 $^\circ C$ the sensor should be protected from knocks by the provision of an additional housing.

When used in group IIC non-permissible electrostatic charges should be avoided on the plastic housing parts.



Instruction

Device category 1D Directive conformity Standard conformity

CE marking

Ex-identification

EC-Type Examination Certificate Appropriate type Effective internal capacitance C_i Effective internal inductance L_i General

Maximum housing surface temperature

Installation, Comissioning

Maintenance

Specific conditions Electrostatic charging for use in hazardous areas with combustible dust 94/9/EG IEC 61241-11:2002: draft; prEN61241-0:2002 type of protection intrinsic safety "iD" Use is restricted to the following stated conditions $C \in 0102$

(x) II 1D Ex iaD 20 T 108 °C (226.4 °F)

ZELM 03 ATEX 0128 X NCN50-FP-N0..

 \leq 220 nF ; a cable length of 10 m is considered.

 \leq 360 μH ; a cable length of 10 m is considered.

The apparatus has to be operated according to the appropriate data in the data sheet and in this instruction manual.

NCN50-FP-N0-P1

The EC-Type Examination Certificate has to be observed.

The special conditions must be adhered to!

The maximum surface temperature of the housing is given in the EC-Type Examination Certificate.

Laws and/or regulations and standards governing the use or intended usage goal must be observed. $% \label{eq:constraint}$

The intrinsic safety is only assured in connection with an appropriate related apparatus and according to the proof of intrinsic safety.

The associated apparatus must satisfy at least the requirements of category ia IIB or iaD. Because of the possibility of the danger of ignition, which can arise due to faults and/or transient currents in the equipotential bonding system, galvanic isolation in the power supply and signal circuits is preferable. Associated apparatus without electrical isolation must only be used if the appropriate requirements of IEC 60079-14 are met.

The intrinsically safe circuit has to be protected against influences due to lightning. When used in the isolating wall between Zone 20 and Zone 21 or Zone 21 und Zone 22 the sensor must not be exposed to any mechanical danger and must be sealed in such a way, that the protective function of the isolating wall is not impaired. The applicable directives and standards must be observed.

No changes can be made to apparatus, which are operated in hazardous areas. Repairs to these apparatus are not possible.

Sliding contact discharges must be avoided. To avoid sliding contact discharges, which are associated with applications involving high charges (e.g. electrostatic enamelling, film manufacture, anti-dust precautions, processes involving mechanical friction, etc.), the surface area of the plastic housing, which is exposed to this charging should be limited to approx. 15 cm2 by appropriate installation measures

Electrostatic charging due to the flow of media during operation must be excluded. This can be achieved by limiting the surface area of the plastic housing exposed to the electrostatic charging to less than 100 cm^2 .

Subject to modifications without notice

USA: +1 330 486 0001 Ger fa-info@us.pepperl-fuchs.com fa-

Germany: +49 621 776-4411 fa-info@pepperl-fuchs.com Copyright Pepperl+Fuchs Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com

