








Model Number

NJ2-11-N-G-Y102883


Features

- · Comfort series
- 2 mm flush

Connection



Dimensions



Technical	Data

General specifications		
Switching element function		NAMUR, NC
Rated operating distance	s _n	2 mm
Installation		flush
Output polarity		NAMUR
Assured operating distance	sa	0 1.62 mm
Reduction factor r _{Al}		0.4
Reduction factor r _{Cu}		0.3
Reduction factor r ₃₀₄		0.85
Nominal ratings		

Nominal ratings	
Nominal voltage	

Nominal voltage	U_{o}	8 V
Switching frequency	f	0 3000 Hz
Hysteresis	Н	0.5 3.5 typ. 2 9
Current consumption		

Measuring plate not detected	≥ 3 mA
Measuring plate detected	≤ 1 mA
Ambient conditions	

Ambient temperature	-25 100 °C (-13 212 °F)

Mechanical specifications cable PVC , 100 mm Connection type

Core cross-section	0.34 mm ²
Housing material	Stainless steel 1.4305 / AISI 303
Sensing face	PVDF
Protection degree	IP68

General information	
Use in the hazardous area	see instruction manuals
Category	2G

Compliance with standards and directives

Standard conformity	
NAMUR EN 60	0947-5-6:2000
IEC 6	0947-5-6:1999
Standards EN 60	0947-5-2:2007
IEC 6	0947-5-2:2007

Approvate una continuateo	
UL approval	cULus Listed, General Purpose
CSA approval	cCSAus Listed, General Purpose

www.pepperl-fuchs.com

ATEX 2G

Instruction

Device category 2G

Directive conformity Standard conformity

CE marking

General

Ex-identification

EC-Type Examination Certificate Appropriate type Effective internal capacitance Ci Effective internal inductance L

Highest permissible ambient temperature

Installation, Comissioning

Maintenance

Specific conditions

Protection from mechanical danger

Electrostatic charging

Manual electrical apparatus for hazardous areas

for use in hazardous areas with gas, vapour and mist 94/9/EG

EN 60079-0:2009, EN 60079-11:2007 Ignition protection "Intrinsic safety"
Use is restricted to the following stated conditions **C**€0102

⟨ II 2G Ex ia IIC T6 Gb

PTB 00 ATEX 2048 X

NJ 2-11-N-G...

≤ 30 nF; a cable length of 10 m is considered.

 $\leq 50~\mu H$; a cable length of 10 m is considered.

The apparatus has to be operated according to the appropriate data in the data sheet and in this instruction manual. The EC-Type Examination Certificate has to be observed. The special conditions must be adhered to!

Directive 94/9/EG and hence also EC-Type Examination Certificates apply in general only to the use of electrical apparatus under atmospheric conditions

The use in ambient temperatures of > 60 °C was tested with regard to hot surfaces by the mentioned certification authority.

If the equipment is not used under atmospheric conditions, a reduction of the permissible minimum ignition energies may have to be taken into consideration.

The temperature ranges, according to temperature class, are given in the EC-Type Examination Certificate

Laws and/or regulations and standards governing the use or intended usage goal must be observed. The intrinsic safety is only assured in connection with an appropriate related apparatus and according to the proof of intrinsic safety.

No changes can be made to apparatus, which are operated in hazardous areas. Repairs to these apparatus are not possible.

When used in the temperature range below -20 °C the sensor should be protected from knocks by the provision of an additional housing.

Electrostatic charges must be avoided on the mechanical housing components. Dangerous electrostatic charges on the mechanical housing components can be avoided by incorporating these in the equipotential bonding.