
# **Dimensions**



NAMUR, bistable

# $\epsilon$






## **Model Number**

## RC15-14-N3-Y115615

## **Features**

- 15 mm inside diameter
- **Comfort series**
- Bistable
- **Direction detection**

## Connection



# **Technical Data General specifications**

Switching element function

Installation	
Output polarity NAMU	JR
Inside diameter 15 mm	n
Measuring cylinder	
Diameter 1/4" (6	6.250mm)
Measuring cone Carbo	loy

Measuring cone Nominal ratings N

Nominal voltage	$U_o$	8 V
Operating voltage	$U_B$	5 25 V
Hysteresis	Н	typ. 1 %
Reverse polarity protection		reverse polarity protected

Current consumption Traverse B 3 mA  $\geq$  3 mA Passage B  $U_B=8V$ Passage B U<sub>B</sub>=10V ≥ 4.2 mA

Traverse A
Passage A U<sub>B</sub>=10V
Passage A U<sub>B</sub>=8V
Time delay before availability 1 mA 0.5 ... 1 mA typ. 0.9 mA 0.5 ... 0.95 mA typ. 0.8 mA ≤ 5 ms

Functional safety related parameters

	•	•	
MTTF <sub>d</sub>			2240 a
Mission T	ime (T <sub>M</sub> )		20 a
Diagnostic	c Coverage (D	C)	0 %

Ambient conditions Ambient temperature 0 ... 40 °C (32 ... 104 °F)

Mechanical specifications cable PVC , 5 m Connection type Core cross-section 0.14 mm<sup>2</sup> Housing material Protection degree PBT IP67

General information

Use in the hazardous area see instruction manuals Category

## Compliance with standards and directives

Standard conformity

otariaara comorniny	
NAMUR	EN 60947-5-6:2000
	IEC 60947-5-6:1999
Standards	EN 60947-5-2:2007
	IEC 60047 F 0:0007

Approvals and certificates

• •	
UL approval	cULus Listed, General Purpose
CSA approval	cCSAus Listed, General Purpose

www.pepperl-fuchs.com

#### ATEX 2G

Instruction

#### Device category 2G

Directive conformity Standard conformity

CE marking

Ex-identification

 $\begin{tabular}{ll} EC-Type Examination Certificate \\ Appropriate type \\ Effective internal capacitance $\,C_i$ \\ Effective internal inductance $L_i$ \\ \end{tabular}$ 

General

Highest permissible ambient temperature

Installation, Comissioning

Maintenance

Specific conditions

#### Manual electrical apparatus for hazardous areas

for use in hazardous areas with gas, vapour and mist 94/9/EG

EN 60079-0:2009, EN 60079-11:2007 Ignition protection "Intrinsic safety"
Use is restricted to the following stated conditions 

€ 0102

⟨ы⟩ II 2G Ex ia IIC T6 Gb

PTB 99 ATEX 2128 X

RC15-...-N3...

 $\leq 90~nF$  ; a cable length of 10 m is considered.  $\leq 70~\mu H$  ; a cable length of 10 m is considered.

The apparatus has to be operated according to the appropriate data in the data sheet and in this instruction manual. The EC-Type Examination Certificate has to be observed. The special conditions must be adhered to!

The temperature ranges, according to temperature class, are given in the EC-Type Examination Certificate.

Laws and/or regulations and standards governing the use or intended usage goal must be observed. The intrinsic safety is only assured in connection with an appropriate related apparatus and according to the proof of intrinsic safety.

No changes can be made to apparatus, which are operated in hazardous areas. Repairs to these apparatus are not possible.