



Features

- · Cast Stainless Steel
- Installation in Zone 1, Zone 2, Zone 21 and Zone 22
- Threaded cable entries
- · Padlockable switch

Dimensions (mm)





| Tecl | nnical | data |
|------|--------|------|
|------|--------|------|

Protection degree Cable entry

Material

Seal

Mass

Enclosure Finish

Number of cable entries

| Electrical specifications | |
|---------------------------|---|
| Operating voltage | 690 V |
| Operating current | 125 A (AC21A) |
| Power | 45 kW (AC23A) 37 kW (AC3) |
| Terminal capacity | 95 mm ² |
| Function | switch disconnetor |
| Number of poles | 6 |
| Auxiliary contacts | 2 x n/o early break |
| Lockable | in 'OFF' position |
| Labeling | OFF - ON |
| Mechanical specifications | |
| Height | 335 mm NOM. |
| Width | 310 mm NOM. |
| Depth | 253 mm NOM. |
| Enclosure cover | hinged non-detachable |
| Cover fixing | M6 stainless steel socket cap head screws |
| Fastener grade | A2-70 |

all entries are fitted with Ex d sealing plugs

IP66

metric threaded

2 x M32 in face B 1 x M20 in face B

cast stainless steel

painted black

approx. 52 kg

by grease

| 435866_eng.xml |
|------------------|
| ue 2013-01-16 |
| Date of issue |
| 2013-01-16 13:11 |
| Release date |

| Mounting | 2 x fabricated stainless steel mounting straps | |
|--|--|--|
| Grounding | internal & external brass grounding terminals on base and lid | |
| Ambient conditions | | |
| Ambient temperature | -40 55 °C (-40 131 °F) | |
| Data for application in connection with Exareas | | |
| EC-Type Examination Certificate | SIRA 04 ATEX 1266X | |
| Group, category, type of protection, temperature class | (x) II 2 GD Ex d IIB T5 Gb, Ex tb IIIC T82°C Db (ta +55°C) | |
| International approvals | | |
| IECEx approval | IECEx SIR 08.0056X | |
| GOST-R approval | GOST-R B01008 | |
| Conformity | | |
| Protection degree | EN 60529 | |
| Switch | switch disconnector to IEC 60947-3 | |
| General information | | |
| Supplementary information | EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl- | |