


## **Features**

- · Coil voltage 240V
- Cast Stainless Steel
- 335 mm x 310 mm x 205 mm
- Suitable for Ex e motors
- Installation in Zone 1, Zone 2, Zone 21 and Zone 22

## **Dimensions (mm)**



## **Technical data**

Fastener grade

Number of cable entries

Protection degree Cable entry

Material Enclosure

Finish

| 11 kW   |
|---|
| 22 A (AC3)  |
| 240 V   |
| 6 mm <sup>2</sup> for flexible cable<br>9.6 mm <sup>2</sup> for solid cable |
| 15 26 A   |
| 3   |
| star delta starter  |
|   |
| 335 mm NOM.   |
| 310 mm NOM.   |
| 205 mm NOM.   |
| hinged non-detachable   |
| M8 stainless steel socket cap head screws                                   |
|   |

A2-70 IP66

metric threaded 1 x M25 in face A

2 x M25 in face B

1 x M20 in face B

cast stainless steel

one piece closed cell neoprene

painted black

approx. 52 kg

all entries are fitted with Ex d sealing plugs

Date of issue 2013-01-21 435897\_eng.xml Release date 2013-01-1721:26

| Mounting   | 2 x fabricated stainless steel mounting straps  |
|--|---|
| Grounding  | internal & external brass grounding terminals on base and lid   |
| Ambient conditions                                     |   |
| Ambient temperature                                    | -40 55 °C (-40 131 °F)  |
| Data for application in connection with Exareas        |   |
| EC-Type Examination Certificate                        | SIRA 04 ATEX 1266X  |
| Group, category, type of protection, temperature class | (x) II 2 GD<br>Ex d IIB T6 Gb, Ex tb IIIC T76°C Db ( ta +50°C )<br>Ex d IIB T5 Gb, Ex tb IIIC T82°C Db ( ta +55°C )   |
| International approvals                                |   |
| IECEx approval   | IECEx SIR 08.0056X  |
| GOST-R approval  | GOST-R B00218   |
| Conformity   |   |
| Protection degree                                      | EN 60529  |
| General information                                    |   |
| Supplementary information                              | EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperlfuchs.com. |