



## **Features**

- · Cast Stainless Steel
- Installation in Zone 1, Zone 2, Zone 21 and Zone 22
- · Threaded cable entries
- · Padlockable switch

## **Dimensions (mm)**





Te	chn	ical	data

Electrical specifications	
Operating voltage	690 V
Operating current	100 A (AC21A)
Power	37 kW (AC23A) 30 kW (AC3)
Terminal capacity	50 mm <sup>2</sup>
Function	switch disconnetor
Number of poles	6
Auxiliary contacts	2 x n/o early break
Lockable	in 'OFF' position
Labeling	OFF - ON
Mechanical specifications	

335 mm NOM.

2 x fabricated stainless steel mounting straps

Pepperl+Fuchs Group • Tel.: Germany +49-621-776-0 • USA +1-330-4253555 • Singapore +65-67-799091 • Internet www.pepperl-fuchs.com

vvidiri	3 TO HILLI NOW.
Depth	253 mm NOM.
Enclosure cover	hinged non-detachable
Cover fixing	M6 stainless steel socket cap head screws
Eastonor grado	A2-70

Fastener grade	A2-70
Protection degree	IP65
Cable entry	metric threaded
Number of cable entries	3 v M25 in face R

all entries are fitted with Ex d sealing plug

Material	
Enclosure	cast stainless stee
Finish	painted black
Seal	by grease
Mass	approx. 52 kg

Subject to reasonable modifications due to technical advances.	

Height

Mounting

⊏
×
÷
$_{2}$
$\subseteq$
437900 eng.xn
0
≍
≍
Ď,
17
ຕາ
4
CO
⋍
١.
÷
Ċ
ᅮ
က်
==
=
2013-01-16
$\alpha$
Φ
$\rightarrow$
ī
ζń
.==
<u>ب</u>
0
Date of issue
$\underline{\mathbf{w}}$
7
~~
ш
0
ᆕ
٠.
က
_
:_
Θ
_
↽
0
ī
က
_
0
N.
2013-01-16 13:10
a)
Ψ.
ਜ਼ਿ
÷
U
9
se
ase o
ease c
lease c
elease
Release of
Release date

Grounding	internal & external brass grounding terminals on base and lid
Ambient conditions	
Ambient temperature	-40 55 °C (-40 131 °F)
Data for application in connection with Ex-	
areas	
EC-Type Examination Certificate	SIRA 04 ATEX 1266X
Group, category, type of protection,	⟨x⟩ II 2 GD
temperature class	Ex d IIB T5 Gb, Ex tb IIIC T82°C Db (ta +55°C)
International approvals	
IECEx approval	IECEx SIR 08.0056X
GOST-R approval	GOST-R B01008
Conformity	
Protection degree	EN 60529
Switch	switch disconnector to IEC 60947-3
General information	
Supplementary information	EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl-